

Disinfectant Level Quarterly Operating Report (DLQOR)*For All Groundwater or Purchased-Water Public Water Systems*

Select Quarter:	Quarter 1 (January, February, March)	Year:	2026
PWS Name:	CityofMunday	PWS ID:	1380003
Type of Disinfectant Used in Distribution System:		Chloramine (Total)	

First Month of Quarter: Monthly SummaryMonth: **January**Was the PWS active this month? ☒ Yes ☐ No

Average of all disinfectant residuals:	Number of residuals collected:	Number of residuals below minimum:	Number of NO residuals:
1.50 mg/L	31 Count	Readings 0.0 %	Readings 0.0 %

Second Month of Quarter: Monthly SummaryMonth: **February**Was the PWS active this month? ☒ Yes ☐ No

Average of all disinfectant residuals:	Number of residuals collected:	Number of residuals below minimum:	Number of NO residuals:
1.50 mg/L	28 Count	Readings 0.0 %	Readings 0.0 %


Third Month of Quarter: Monthly SummaryMonth: **March**Was the PWS active this month? ☒ Yes ☐ No

Average of all disinfectant residuals:	Number of residuals collected:	Number of residuals below minimum:	Number of NO residuals:
1.50 mg/L	31 Count	Readings 0.0 %	Readings 0.0 %

Quarterly Summary and Certification

Average of all disinfectant residuals for this quarter	LOWEST disinfectant residual for this quarter	HIGHEST disinfectant residual for this quarter
1.50 mg/L	1.10 mg/L	1.90 mg/L

☒ I certify that I am familiar with the information contained in this report and that, to the best of my knowledge, the information is true, complete, and accurate.

Name: **Robert Serrato**Date: **2026 07 22**Signature: Title and Phone Number: **Munday PW Director at**Water Operator License Number: **WD0018496**Email: **citymanager@mundaytexas.com**

Complete this form for the previous quarter at the beginning of April, July, October, and January; and submit in time for it to be received by the TCEQ by the 10th of the month. Always print and sign form and keep a copy with your records for TCEQ review during onsite investigations.

Sign the DLQOR and mail to:

Certified Mail: TCEQ/DWSS MC-155, Attn: DLQOR, 12100 Park 35 Circle, Bldg F, Austin, TX 78753-1808

Regular Mail: TCEQ/DWSS MC-155, Attn: DLQOR, P.O. Box 13087, Austin, TX 78711-3087



Texas Commission on Environmental Quality

Protecting Texas by Reducing and Preventing Pollution

June 30, 2026

Delivered Via Regular Mail DWQ/NOV/27/0999

CITY OF MUNDAY
CHRIS BAKER, MAYOR
PO BOX 39
MUNDAY, TX 76371-0039

SUBJECT: Notice of Violation: CHLORINE MONITORING, ROUTINE (DBP), MAJOR
30 TAC § 290.110(e)(4)(A), § 290.110(f)(3) - Failure to Submit Disinfectant Level Quarterly Operating Report
CITY OF MUNDAY - PWSID: 1380003
KNOX County, TX

This letter contains important information about compliance requirements for your public water system.

Attention: Public Water System Owner / Manager / Operator

The Texas Commission on Environmental Quality (TCEQ) has determined that CITY OF MUNDAY has a monitoring/reporting violation for failing to monitor the disinfectant residual within the distribution system or failing to submit a Disinfectant Level Quarterly Operating Report (DLQOR) to the TCEQ for the following compliance period, first quarter of 2026, as described in Title 30, Texas Administrative Code (30 TAC), §290.110. The attached Violation Report summarizes each violation by monitoring period and rule.

In accordance with Title 30, Texas Administrative Code (30 TAC) §290.122(c), your public water system is required to issue public notification to your customers about the monitoring/reporting violation(s) as soon as possible, but not later than twelve months after the date the violation(s) was identified. The public notice must use the enclosed mandatory language for every notice, and include a brief statement about what you plan to do to fix the problem as described in 30 TAC §290.122(d). This statement must describe what actions the water system is taking to correct the violation, and when the water system expects to return to compliance.

You are required to repeat the notice every twelve months for as long as the violation persists. You should use the same method that you used for the initial notice. Please send a copy of the public notification and a signed Certificate of Delivery for Public Notice to this office within 10 days after it has been delivered. Mail to:

TCEQ - Drinking Water Inventory & Protection Team
Attn: Public Notice (MC-155)
P.O. Box 13087
Austin, TX 78711-3087

Please note that enforcement actions resulting from noncompliance may result in fines for each violation(s).

Monitoring/Reporting Violation Report:
CITY OF MUNDAY PWS ID: TX1380003

DS01		DISTRIBUTION SYSTEM	
First Quarter 01/01/2026 - 03/31/2026			
<u>Analyte Code</u>	<u>Violation ID</u>	<u>Analyte</u>	<u>Rule Citation</u>
0999	381	CHLORINE	30 TAC § 290.110(e)(4)(A), § 290.110(f)(2), § 290.110(f)(3) - Failure to Submit Disinfectant Level Quarterly Operating Report